

Proceedings of the Korean Nuclear Society Spring Meeting
Pohang, Korea, May 1999

Heat Transfer in a One-Dimensional Mixed Convection Loop

Min-Joon Kim, Yong-Bum Lee, Yong-Kyun Kim, Jong-Man Kim, and Ho-Yun Nam

Korea Atomic Energy Research Institute
150 Dukjin-dong, Yusong-gu, Taejon, Korea 305-353

Abstract

Effects of non-uniform heating in the core and additional forced circulation during decay heat removal operation are studied with a simplified mixed convection loop. The heat transfer coefficient is calculated analytically and measured experimentally. The analytic solution obtained from a one-dimensional heat equation is found to agree well with the experimental results. The effects of the non-uniform heating and the forced circulation are discussed.