# Criticality Evaluation of Model UO2 Fuel Concerning Voloxidation Process

Fanxing Gao, Won Il Ko, Chang Je Park

Korea Atomic Energy Research Institute, 1045, Daedeok-daero, Yuseoung-gu, Daejeon, 305-353, Korea

nwiko@kaeri.re.kr

#### 1. Introduction

Criticality safety evaluation is of great importance in the design of voloxidation apparatus, the result of which determines the size of the apparatus as well as the capacity. However, there are fewer studies reported on the criticality evaluation of the voloxidation process. Based on the fundamental principles of the performance of criticality evaluation and assessment of methods used by other criticality evaluations concerning several related facilities such as transport container of nuclear fuel [1], the packaging of spent nuclear fuels [2], the spent fuel storage pool [3], the criticality evaluation of voloxidation process has been performed. The tool used is MCNPX code which is widely employed in the criticality safety evaluation [4]. The structure of a real voloxidation apparatus is complicated and difficult to be set as the input of the MCNPX code directly. The distribution of reactant in the cell is assumed to affect the results. So the selection of a proper geometry and optimization of the distribution of the reactants plays an important role in obtaining highly reliable results. In this paper, a simplified model in which the geometries of the reactant and container are both defined as cylinder has been adopted. As conservative results are always preferred in the criticality evaluation, the voloxidation apparatus is assumed to be surrounded by sufficiently thick water layer which functions as not only the neutron moderator but also the reflector [1, 5]. Fresh UO2 fuel with an enrichment of 4.5 w% 235U and a specified PWR spent fuel the initial enrichment of which is 4.5 w% 235U with a burnup of 50GWd are adopted as the evaluation objects respectively. The reason for the employment of fresh UO2 is that it contains almost no neutron poisons and offers a relatively conservative result.

## 2. Setup of Evaluation Model

In this paper, the volume of the spent fuel is the summation of volumes of  $UO_2$  and TRU oxides. Density of the spent PWR is calculated to be  $10.97~g/cm^3$ . The main chemical reaction of the voloxidation process is  $3UO_2+O_2=U_3O_8$ , so the more  $O_2$  charged, the more complete the  $UO_2$  pellets converted into  $U_3O_8$  powder. The density of the mixture, or  $UO_x$  powder uniformly mixed with  $O_2$ , during voloxidation operation was determined to be  $1.10~g/cm^3$  by the same method assuming the charge ratio of solid phase oxides to gas phase  $O_2$  is 1 to 9.

In order to simulate most of the possibilities in regarding to not only normal but also abnormal situations, totally 6 cases were proposed for the determination of the final geometry used for evaluating criticality as illustrated in Table 1. Multiplication factors of a fresh UO<sub>2</sub> fuel was calculated employing these 6 geometries respectively shown in Table I as well. Finally #4 with the biggest K-effective value has been selected as the most conservative geometry to perform the criticality evaluation. The relationship between the multiplication factors of homogeneous case and solid-gas phase case depending on the increase of mass is not regular and the differences are negligible. Criticality evaluation of the fresh UO<sub>2</sub> and the spent fuel was carried out based on the #4 case with regarding fuel particulate system as a homogeneous phase substance.

#3 Fuel #2 Fuel & SS304 container without lid #1 Fuel & SS304 container

K-effective=0.04889±0.00016 K-effective =0.05840±0.00041 K-effective =0.06066±0.000195


Table 1 Model of 6 Cases

#4 Fuel surrounded by water	# 5 Fuel & SS304 container without lid surrounded by water	#6 Fuel & SS304 container surrounded by water
		and the second second
K-effective =0.42220±0.00347	K-effective =0.18649±0.00232	K-effective =0.08086±0.000875

\*A stands for the fresh UO<sub>2</sub> fuel. B stands for the walls of the apparatus made of SS304. C stands for water. Thickness of water is 15 cm. Standard deviations are associated with 95% confidential.

#### 3. Results and discussion

The values of the neutron multiplication factors obtained of  $2000 \text{ kg } \text{UO}_2$  input scale is less than 0.7 which is smaller than the maximum permissible multiplication factor of 0.95 correspondingly no criticality risk. From mathematical point of view, the limit of the trend line equation is less than 0.8, so it seems there is no mass limitation of  $\text{UO}_2$  concerning the criticality risk during the fresh  $\text{UO}_2$  and PWR spent fuel voloxidation process.



\$\frac{1}{2} \quad \frac{1}{2} \quad \frac{1}{2}

Fig.1. K-effective of fresh UO2 and SF with Model #3.

Fig.2. K-effective of UO2 surrounded by water.

### 4. Conclusions

Fresh  $UO_2$  with an enrichment of  $4.5 \text{w}\%^{235}U$  and a specified PWR spent fuel were adopted respectively as the reference fuels. 6 cases simulating the probable geometries of the apparatus was built and juel particles distribution in the apparatus was also estimated. It is proposed that there is no criticality risk concerning the voloxidation process. Based on the evaluation procedures and methods developed in this work, further work will be carried out to evaluate the criticality safety of other apparatus of pyroprocess such as electro-reducer, electro-refiner, and electro-winner etc.

# References

- 1. W. Jahreiß, U. Philippczyk, W. Paulinyi et al. A New Transport Container for Fresh PWR Fuel Assemblies According to IAEA Requirements.
- Criticality safety of spent nuclear fuel assemblies from the transmutation of minor actinides in fast reactors
   Nicolaou , N. Tsagas. Annals of Nuclear Energy 33 (2006) 305–309
- E. Massoud, O. H. Sallam, E. Amin. Criticality of the ET-RR-1 new spent fuel storage pool. Annals of Nuclear Energy, Volume 28, Issue 4, March 2001, Pages 375-383
- 4. Charles D. Harmon, II et al., "Criticality Calculations with MCNP:A Primer", LA-12827-M, 1994.
- 5. IAEA Safety Standards, Safety of Nuclear Fuel Cycle Facilities, safety requirements No.NS-R-5. Page 30-31